

CITY OF REEDLEY
Fax #: 559.637.2139
Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

RFI # 11

Date: 9/13/2018 Time: 2:08 PM

Company: Smith Construction Company, Inc.

Contact Person: Don Smith

Address: 2139 N Briarwood Ave. Fresno, CA 93705

Telephone: 559-233-1515 Fax: 559-233-1551

Plan Sheet: 9 of 20 Detail L: Boarding Float Position - Profile View

Specification Section: 10-28 Steel Pipe Piles

INTERPRETATION REQUESTED:

On the plans L/9 shows 5 steel piles, Bid Schedule 28 (7 of 28) has 4 ea. Which is correct? Also the plans and specs do not call out the wall thickness of the the steel pile, please provide the wall thickness.

REPLY:

The pile diameter was provided in the specifications as 1.0 outer diameter and the inner diameter is 0.96 feet, the wall thickness would be 1/4 inch.


City Engineer

All requests and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed to plan holders.