

**CITY OF REEDLEY**  
**Fax #: 559.637.2139**  
**Email Address: [salina.gonzalez@reedley.ca.gov](mailto:salina.gonzalez@reedley.ca.gov)**

**Request for Interpretation of Contract Documents**  
**R.F.I. # 07.**

Date: 09/10/2018. Time: 2:33 P.M.

Company: SMITH CONSTRUCTION COMPANY INC.

Contact  
Person: Don Smith

Address: 2139 N. Briarwood Ave. Fresno. Ca. 93705

Telephone: 559-233-1515 Fax: 559-233-1551

Plan Sheet: 9 & 10 of 20. Details K/9 & R/10


Specification Section: 10-23 ROCK SLOPE PROTECTION- 2.2 GROUTED RIP RAP

**INTERPRETATION REQUESTED:**

Plans do not call out grouted Rip Rap but the specs do mention it. Do you want the 1/4 ton rip rap grouted?

**REPLY:**

Rip rap shall be grouted as stated in Section 10-23-2.2.

  
\_\_\_\_\_  
City Engineer

All requests and replies will be published on the City's web site at: [www.reedley.ca.gov](http://www.reedley.ca.gov) in addition to being faxed to plan holders.