

**CITY OF REEDLEY**  
**Fax #: 559.637.2139**  
**Email Address: salina.gonzalez@reedley.ca.gov**  
**Request for Interpretation of Contract Documents**  
**RFI # 09**

Date: 9/13/2018 Time: 9:50 am

Company: Smith Construction Company, Inc.

Contact  
Person: Don Smith

Address: 2139 N. Briarwood Ave, Fresno, CA 93705

Telephone: 559-233-1515 Fax: 559-233-1551

Plan Sheet: 13 of 20 Detail GG & 14 of 20

Specification Section: 10-33 Boarding Floats - 2.1 Materials - Item E Hinges (Pg. 153)

**INTERPRETATION REQUESTED:**

California Custom Docks calls out on page 153 Schedule 80 XXS is an error. Request clarification if 10-33 2.1 Item E: Hinges is to be 2" SCH 80 or 2" XXS. The XXS pipe is not a stock item in Stainless Steel, and will be very difficult to find and a premium price if found. Please advise.

**REPLY:**

Boarding float dock hinge pin, change the hinge pin to Sch 80 Steel pipe 1 1/2 inch diameter with 1 1/4 inch pin, hot dipped galvanized.

  
\_\_\_\_\_  
City Engineer

All requests and replies will be published on the City's web site at: [www.reedley.ca.gov](http://www.reedley.ca.gov) in addition to being faxed to plan holders.