

CITY OF REEDLEY

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 9/20/19 Time: 10 AM

Company: Golden Bay Fence

Contact Person: Mike Young

Address: 4104 S. B St., Stockton, Ca. 95206

Telephone: 209-944-9754 Fax: 209-944-5812

Plan Sheet: CD1 detail 5

Specification Section: 10-1.06 Bollard

INTERPRETATION REQUESTED: Detail and specs call for a 4" OD steel post (10.79 lb/ft). This is not the correct weight for a 4" OD steel pipe. 4 1/2" OD steel pipe weighs 10.79 lb/ft. 4" weighs 9.12 lb/ft. Are we to use 4" or 4 1/2" steel posts for the bollards.

REPLY: 4" O.D. (9.12 lb/ft) steel post for the bollards can be used.

Salina Gonzalez 9/20/19

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.