

CITY OF REEDLEY

RFI No 6

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 9/20/19

Time: 10 AM

Company: Golden Bay Fence

Contact Person: Mike Young

Address: 4104 S. B St., Stockton, Ca. 95206

Telephone: 209-944-9754 Fax: 209-944-5812

Plan Sheet: CD1 detail 5

Specification Section: 10-1.07 -3/8" grade 30 chain

INTERPRETATION REQUESTED: Please clarify how the chain is to be attached to the line posts. Is the chain to be stretched taught or have a droop? If so how much droop is there supposed to be between posts?

REPLY: Refer to section 10-1.07 - 3/8" Grade 30 zinc plated. At each end of chain, use 3/8" zinc plated double ended bolt snap to connect to 3/8" bolt on bollard.

Sal G 9/20/19

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.