

CITY OF REEDLEY

RFI No 10

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 5/7/2020

Time:

Company: Pac-West Construction

Contact Person: Rick

Address: P.O. 736 Chowchilla, Ca. 93610

Telephone: (559)706-7200 Fax:

Plan Sheet: Plan Sheet 9 of 10 (Lightspeed Electric & Utility Design)

Specification Section:

INTERPRETATION REQUESTED:

Sheet 9 General Note States Conduits Crossing Myrtle to be Installed by Jack and Bore Method. Is Horizontal Directional Drill Method Acceptable?

REPLY: Horizontal Drill Method is acceptable for the installation of the conduits

John 5/8/20

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.