

CITY OF REEDLEY

RFI No 11

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 5/7/2020

Time: _____

Company: Pac-West Construction

Contact Person: Rick

Address: P.O. 736 Chowchilla, Ca. 93610

Telephone: (559)706-7200 Fax: _____

Plan Sheet: Plan Sheet 10 of 10 (Lightspeed Electric & Utility Design)

Specification Section: _____

INTERPRETATION REQUESTED:

Sheet 10 Indicates Street Light Power to be supplied Via Secondary Pull Box at Lot 11 / 12 is there a conduit stub to be tied into? If Not are we to stub Conduit Clear of Ultimate Improved Radius and Sidewalk Adjacent to end of CMU Block Wall on South East Corner of Buttonwillow and Myrtle for Future Tie Point?
For clarification the only conduit to be installed down Myrtle and to service point at Lot Line 11 /12 is the street light conduit, is this correct?

REPLY: There is not a conduit stub to tie into.
Conduit is to be extended to the Point of
Service on Valencia Avenue.

John W 5/8/20

Yes, only the street light conduit.

John W 5-11-20

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.