

CITY OF REEDLEY

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 5/8/2020

Time:

Company: Pac-West Construction

Contact Person: Rick

Address: P.O. 736 Chowchilla, Ca. 93610

Telephone: (559)706-7200

Fax:

Plan Sheet: Plan Sheet 8, 9, & 10 (Lightspeed Electric & Utility Design)

Specification Section:

INTERPRETATION REQUESTED:

Bid Item 27 References PG&E Vault and there is one indicated on Lightspeed drawing sheet 3 of 3 page 9 of Bid Plan Set, PG&E Rule 20 does not indicate a vault at this location. Are we to include pricing to furnish and install for this item?

REPLY: Install vault per PG&E Rule 20 plan sheet. Referenced as secondary enclosure (17" x 30" x 26"). Bid Item # 27 includes pricing to furnish and install.

John W 5-8-20

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.