

CITY OF REEDLEY

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 5/8/2020 Time: \_\_\_\_\_

Company: Pac-West Construction \_\_\_\_\_

Contact Person: Rick \_\_\_\_\_

Address: P.O. 736 Chowchilla, Ca. 93610 \_\_\_\_\_

Telephone: (559)706-7200 Fax: \_\_\_\_\_

Plan Sheet: Plan Sheet 8, 9, & 10 ( Lightspeed Electric & Utility Design ) \_\_\_\_\_

Specification Section: \_\_\_\_\_

INTERPRETATION REQUESTED:

Bid Item 27 References PG&E Vault and there is one indicated on Lightspeed drawing sheet 3 of 3 page 9 of Bid Plan Set, PG&E Rule 20 does not indicate a vault at this location. Are we to include pricing to furnish and install for this item? The vault in question is indicated to be 6'X8' on sheet 3 of 3 (Lightspeed), page 9 of plan sheets at approximate Sta. 13+10 of Buttonwillow this would be a 600 amp primary enclosure not 17X30X26 secondary enclosure. Again this is not shown on PG&E Rule 20 Drawings meaning there are no indications of conduits being terminated in this vault. Is it the intent to have contractor furnish and Install Vault?

REPLY: Install vault per PG&E Rule 20 plan sheet. Referenced as secondary enclosure (17" x 30" x 26"). Bid Item # 27 includes pricing to furnish and install. J. M. 5-8-20

The Vault on sheet 3 of 3 (Lightspeed) is not to be furnished and installed by contractor. J. M. 5-11-20

All request's and replies will be published on the City's web site at: [www.reedley.ca.gov](http://www.reedley.ca.gov) in addition to being faxed and/or emailed to plan holders.