

CITY OF REEDLEY

RFI No 3

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

Request for Interpretation of Contract Documents

Date: 05/04/2020

Time: 3:00 pm

Company: R.J. Berry Jr., Inc.

Contact Person: Mitch DeFreitas

Address: P.O. Box 468, Selma, CA 93662

Telephone: (559) 896-1680 Fax: Email: estimating@rjberry.net

Plan Sheet: Drawing 2 of 3

Specification Section: N/A

INTERPRETATION REQUESTED:

Section A-A and Section B-B on the Demolition, Grading, and Site Plan (Drawing 2 of 3) show the Aggregate Base extending under the Curb & Gutter. It does not appear the Final Pay quantity for Pay Item 8 includes the Aggregate Base under the Curb & Gutter.

Please confirm whether or not the intent it to extend the Aggregate Base section under the Curb & Gutter.

REPLY: No aggregate base is required to be placed under the curb and gutter. Curb and gutter to be installed per city standard ST-8

[Signature] 5-5-20

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.