

CITY OF REEDLEY

Fax #: 559.637.2139

Email Address: salina.gonzalez@reedley.ca.gov

RFI No 9

Request for Interpretation of Contract Documents

Date: 5/8/2020

Time: _____

Company: Pac-West Construction

Contact Person: Rick

Address: P.O. 736 Chowchilla, Ca. 93610

Telephone: (559)706-7200 **Fax:** _____

Plan Sheet: Plan Sheet 8, 9, & 10 (Lightspeed Electric & Utility Design)

Specification Section: _____

INTERPRETATION REQUESTED: _____

Sheet 8 Trench Section D-21 Indicates (1) Telephone, & (1) Cable. Please disclose information from these utility providers on size and confirming quantity.

REPLY: No conduits for Verizon is to be installed. See Addendum # 3.

Install 2-2" conduit from STA 09+70 Power Pole w/ pull rope to conduits at STA 10+40, 50' L then 2-2" conduit from STA 10+40, 50' L to STA 13+70. All conduits shall have pull ropes.
John M 5/11/20

All request's and replies will be published on the City's web site at: www.reedley.ca.gov in addition to being faxed and/or emailed to plan holders.